

# Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



## Test Report

No. 15-002949-PR01

(PB-A01-02-en-02)

<b>Client</b>	EXALCO S.A. 5th Km of National Road Larisa-Athens 41110 Larisa Greece
<b>Product</b>	Fixed light
<b>Designation</b>	System designation: ALBIO 125 C
<b>Performance-relevant product details</b>	Material: Aluminium profiles with thermal break
<b>Overall dimensions (W x H)</b>	1,105 mm x 2,200 mm
<b>Special features</b>	Compatibility of materials must be taken into account. Material durability must be taken into account.

### Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Corresponds to the national standard/s (e.g. DIN EN)

Replaces Test Report

15-002949-PR01 (PB-A01-02-en-01) dated 25.11.2015

### Representation



### Instructions for use

The manufacturer is allowed to use the results obtained for preparing a Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EC. Observe the specifications set out by the applicable product standard.

### Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

### Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 17 pages.

### Results

Air permeability according to EN 12207:1999-11



**Class 4**

Watertightness according to EN 12208:1999-11



**Class E1500**

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



**Class C4 / B4**

ift Rosenheim

10.12.2015

Andreas Graf, MSc, Dipl.-Ing. (FH)  
Deputy Head of Testing Department  
Construction Product Testing

Thomas Stefan, Dipl.-Ing. (FH)  
Operating Testing Officer  
Construction Product Testing