

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No.15-001170-PR02

(PB-A01-02-en-01)

Client	EXALCO S.A. 5th Km of National Road Larisa-Athens 41110 Larisa Greece
Product	Tilt and turn window with fixed sidelight
Designation	System designation: Albio 127C
Performance-relevant product details	Material: Aluminium profiles with thermal break
Overall dimensions (W x H)	1.500 mm x 1.500 mm
Special features	Locking situation.

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E1500

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C4 / B4

Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 22 pages.

ift Rosenheim

28.04.2015

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Construction Product Testing

Thomas Krichbaumer
Operating Testing Officer
Construction Product Testing